

State of Oregon
Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered.

Requests shall be submitted to the Well Construction Specialist,
Water Resources Department, 290 N. Central Street, Coquille, OR
97423. Requests may also be considered by the appropriate Regional
Manager.

SKYLES DRILLING, INC.

Date of request: December 29, 1995

Bonded Well Constructor (name and license): Steven C. Bland
License #1592

(1) Location of Well: SW 1/4 NE 1/4 of Section 32
Township 3 S., Range 1 E., Clackamas County.
Address at well site: 7501 Knights Bridge Rd.
Canby, OR

(2) Name and Address of Land Owner: Canby Grove Conference
Center (Keith Johnson), 7501 Knights Bridge Rd., Canby, OR 97013

(3) The distance to the nearest well, septic tank or drainfield:
Over 180 feet from tank, 200 feet from drainfield + 15 feet from well.
Note this well is scheduled to be abandoned in January 1996 then nearest well
(4) The unusual conditions which necessitate this request: over 200 feet
10 inch casing didn't pull all the way out.

(5) The proposed construction methods that the well constructor
believes will be adequate for this well (attach additional
pages if needed). The well is sealed from 181 feet
to 186 feet for a lower seal. Also sealed
from 49 feet to 27 feet for the upper seal.
Sealed inside 10 inch from 27 feet to 3 feet. Cut off
10 inch casing 3 feet below ground level and
Seal from 3 feet to ground level.


SKYLES DRILLING, INC.

W-CA

Skyles Drilling, Inc.
1169 Molalla Ave.
Oregon City, OR 97045
658-2683

- (6) Start Card #: (7) Diagram showing the pertinent features of the proposed well design and construction:

82919



Signed: Steven C. Bland
(Bonded Constructor)

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the above signed shall return to the site and rectify the problem.

For Water Resources Department Use Only

Date:

1-3-95

Approved by:

[Signature]

Denied by:

Remarks: