



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building

725 Summer St. NE, Suite A

Salem, OR 97301

Phone: 503-986-0900

FAX: 503-986-0904

www.oregon.gov/owrd

October 11, 2012

JONES DRILLING CO. INC.
BRET S JONES WWC 1684
29400 SANTIAM HWY
LEBANON, OR 97355

FINAL ORDER


Dear Bret:

The Special Standards Request Form you submitted for owner: Jackass Mountain Ranch, Start Card number 1018006, is hereby approved for the following: You may construct this 32 foot deep water supply well with a minimum 12 foot annular seal as described on your Special Standards Request Form. The seal shall be cement grout from 0 to 10 ft bgs and unhydrated bentonite from 10 ft bgs to 12 ft bgs. Your Special Standards Request Form is enclosed. All other standards must be adhered to. This special standard was verbally approved by on October 5, 2012.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrdd.state.or.us.

Sincerely,



Kristopher Byrd, Coordinator
Well Construction Program
Oregon Water Resources Department

enclosure

cc: Bill Ferber, W Region Manager
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards
Request Form

RECEIVED

OCT 08 2012

WATER RESOURCES DEPT
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted
to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE,
Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional
Manager.

Date of request: 10-5-12 Oral approval date (if applicable): 10-5-12

Bonded Well Constructor (name, license #, and mailing address): Bret Jones
1684 29400 Smtain Hwy Lebanon or 97355

(1) Location of Well: SE 1/4 NE 1/4 Tax lot 101 Section 17,
Township 10 S, Range 3 W, Linn County
Address at well site: 7048 NE Parker lane
Albany or 97321

(2) Start Card Number(s)(for work to be done): 1018006


(3) Name and Address of Land Owner: Jackass Mountain Ranch
Dave & Cliff Machugh

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
Over 100'

(5) The unusual site conditions which necessitate this request: Sandstone
To shallow for Irrigation well in the Gravel
formation deeper Gravels has too much clay to make
enough water

(6) The proposed construction methods that the bonded well constructor believes will be
adequate for this well: (attach additional pages if needed)
Cement seal 10' to 10' Bentonite seal from
10' to 12' perforations from 12 to 32'

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



RECEIVED
OCT 08 2012
 WATER RESOURCES DEPT
 SALEM, OREGON

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

A handwritten signature in black ink, appearing to be 'B. Jones', written over a horizontal line.