

STATE OF OREGON
WATER RESOURCES DEPARTMENT

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,
NE, Salem, OR 97310.

Date: 5/30

Well Constructor: CHRISTENSEN WELL DRILLING CO
33132 COLMAN RD, EUGENE, OR 97401

(1) Location of Well: NW 1/4 SE 1/4 of Section 1,
Township T18S, Range 3W, LANE County.

Address at well site or nearest known address: WILLAMETTE Well field
SEAVEY RD
SPRINGFIELD, OR

(2) Name and address of Landowner: Springfield Utility Board
PO Box 300
Springfield, OR 97477

(3) The distance to the nearest well and septic drainfield: _____

(4) The unusual conditions existing at the well site: OPEN GRAVELS
IN SEAL AREA

(5) The proposed construction methods that the well constructor or landowner
constructing the well believes will be adequate for his particular well:
USE "Chunky" Bentonite IN SEAL AREA
SEAL to 18'

W-201
5041050

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):

(Signed) Paul Christensen
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date:

6-4-91

Approved by:

[Signature]

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.

84150