

September 13, 1993

en

WATER
RESOURCES
DEPARTMENT

Chuck Nugent
Nugent Drilling Co.
36969 Rock Hill Drive
Lebanon, OR 97355


Dear Chuck:

The Water Resources Department has received your request for special standards on the Halcyon Villa Mobile Park well located in Township 12S, Range 2W, Section 24 of Linn County.

Due to difficult drilling conditions and the presence of poor quality water in the area, you are proposing to seal 8 inch casing from 30 feet to land surface with 3/4 bentonite. Your request is hereby approved. If, however, after testing the water is discovered to be contaminated, you will be required to remove the 8 inch casing, construct a 12 inch bore hole to proper depth and seal the well with cement grout.

If you have any questions concerning this letter, please contact me at the address or phone number listed below.

Sincerely,



Rob Carter
Well Construction Specialist

cc: Gene McGinnis, Watermaster
Richard Edwards, Well Inspector

halcyon



3850 Portland Rd NE
Salem, OR 97310
(503) 378-3739
FAX (503) 378-8130

STATE OF OREGON
WATER RESOURCES DEPARTMENTREQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,
NE, Salem, OR 97310.

Date: 9-10-93

Well Constructor: NUGENT DRILLING Co.
36969 Rock Hill Dr. Lebanon, ORE

(1) Location of Well: 1/4 1/4 of Section 24,
Township 12S, Range 2W, LinN County.

Address at well site or nearest known address: 38129 WEIRICH Rd.
LEBANON, ORE 97355

(2) Name and address of Landowner: HALCYON Villa Maple Park
38129 WEIRICH Rd.
LEBANON, ORE 97355

(3) The distance to the nearest well and septic drainfield: 350' to
SAND FILTER SYSTEM

(4) The unusual conditions existing at the well site: BAD WATER IN
AREA.

(5) The proposed construction methods that the well constructor or landowner
constructing the well believes will be adequate for his particular well:

USE 3/4 inch 30' - 12" GROUT HOLE TO
STOP upper water from following pipe to lower water.
and still be able to move 8" casing if water leaks out
BAD.

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):

(Signed) Chas. O. [Signature]
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date: 9-13-93

Approved by: [Signature]

Denied by: _____

Remarks: _____

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.