

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 1-8-02 Oral approval date (if applicable): 1-8-02

Bored Well Constructor (name, license #, and mailing address): Doug Dungeen
#1575 24550 So Poe Valley Rd. K-Falls Or 97603

(1) Location of Well: SW 1/4 NE 1/4 of Section 35

Township 40 N(S) Range 11 E(W) Klamath County.

Address at well site: 24550 So Poe Valley Rd. K-Falls Or 97603

(2) Start Card Number(s): 46596

(3) Name and Address of Land Owner: David Oxley
24550 So Poe Valley Rd K-Falls Or 97603

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): _____

(5) The unusual conditions which necessitate this request: reached maximum depth with my well rig and need to vent side air. It takes weeks to get and weather is not permitting at this time. Would like to temporarily leave well site

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

I am leaving a 30' 9" starter pipe in the ground with a cap on it.

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.444. Any petition for judicial review of the order must be filed within the time specified by ORS 183.484(2).

W-DR
RECEIVED

JAN 14 2002

WATER RESOURCES DEPT.
SALEM, OREGON

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature:

[Handwritten Signature]

For Water Resources Department Use Only

Date: 1-8-02

Approved by: *[Signature]* Denied by: _____

Remarks: Not to exceed 3 weeks without contacting the region office.