

e

STATE OF OREGON
WATER RESOURCES DEPARTMENT

RECEIVED
OCT 10 1990
WATER RESOURCES DEPT
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road, NE, Salem, OR 97310.

Date: 10/6/90

Well Constructor: R. Stadel & Sons, Inc. by Paul R. Stadel
11304 Evergreen Rd. N.E. Silverton, Ore. 97381

(1) Location of Well: N.E. 1/4 N.W. 1/4 of Section 34,
Township 8S, Range 1W, Marion County.

Address at well site or nearest known address: 8213 Cascade Hwy. S.E.
Sublimity, Or. 97385

(2) Name and address of Landowner: Michael & Lola Stuckart
8213 Cascade Hwy. S.E.
Sublimity, Or. 97385

(3) The distance to the nearest well and septic drainfield: Brainfield
is over 100ft maybe 200ft away & nearest well must be 500' or 600'

(4) The unusual conditions existing at the well site: water is contaminated
and we could see water approx 5 gpm running in below 10" casing
at 48ft.

(5) The proposed construction methods that the well constructor or landowner constructing the well believes will be adequate for his particular well:


We drove the 10" casing about 2 1/2" to 3" down & shut the water
off & now we would like to install 8" casing to 59 ft. in
hard grey shale as the old well log terms it with a flint
at the bottom & some 4 minus & then cement grout it to surface
& have centering guides on the 8" pipe with .250 wall thickness
& we will weld a plate around the 8" on top of 10" to let the
8" rest on.

Sc 18593

w-OT, as

remark - repair

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



(Signed) Paul R. Stadel
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date: 10-11-90

Approved by: [Signature]

Denied by: _____

Remarks: _____

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.