



Oregon

Kate Brown, Governor

Water Resources Department

725 Summer St NE, Ste A

Salem, OR 97301

Phone: 503-986-0900

Fax: 503-986-0904

October 30, 2020

JACK ABBAS WWC #1720
ABBAS WELL DRILLING CO
PO BOX 2130
TERREBONNE, OR 97760

FINAL ORDER

Dear Mr. Abbas:

The Special Standards Request Form you submitted for owner: City of Sisters, Start Card number: 1049398 is hereby approved for the following: You may place a bentonite annular seal from 170 feet to 160 feet below land surface through more than 50 feet of standing water, as described on your Special Standards Request Form dated October 26, 2020. A copy of your Special Standards Request Form is enclosed. All other well construction standards must be adhered to.

Verbal approval of this Special Standard Request was provided by Kris Byrd on October 26, 2020.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852, or by e-mail at Travis.N.Kelly@oregon.gov.

Sincerely,

Travis Kelly, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: William Nashem, Well Inspector, SC Region

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 10-26-20 Oral approval date (if applicable): 10-26-20

Bonded Well Constructor (name, license #, and mailing address): Jack Abbas,
#1720, P.O. Box 2130 Terrebonne OR 97760

(1) Location of Well: SE 1/4 NE 1/4 Tax lot 401 Section 9,
 Township 15s #, Range 10E #, Desch County
 Address at well site: 504 S Locust St Creek side Camp ground

(2) Start Card Number(s)(for work to be done): 1049398


(3) Name and Address of Land Owner: City of Sisters Well #4
525 E Cascade Ave PO Box 39 Sisters, OR 97759

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
200' +

(5) The unusual site conditions which necessitate this request: Loss of cement
Grout

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
Pour 3/4" bentonite from 170' up to 160'

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____