



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building

725 Summer St NE, Suite A

Salem, OR 97301

Phone (503) 986-0900

Fax (503) 986-0904

www.wrd.state.or.us

March 29, 2016

STEVEN C. BLAND WWC #1592
SKYLES DRILLING INC.
21912 BEAVERCREEK ROAD
OREGON CITY, OREGON 97045

FINAL ORDER


Dear Mr. Bland:

The Special Standards Request Form you submitted for owner: Adam Cuff, Start Card number 212776, is hereby approved for the following: You may construct this water supply well within 80 feet from the nearest existing septic drain line at the location marked on the site and verified by the regional well inspector. The well shall be continuously cased and sealed to a minimum depth of 185 feet below land surface and sealed at least 10 feet into the consolidated confining formation overlying the water bearing zone. *A stipulation of this Special Standards Request approval is that a rough drilling log with the static water level be provided to me prior to sealing the well in order to verify that the sealing interval is appropriate.* All other setbacks requirements must be met.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@wrd.state.or.us.

Sincerely,


Joel Jeffery, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Barry Sanford, NW Region Well Inspector
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

SALEM, OR

MAR 18 2016

RECEIVED BY OWRD

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 3-16-2 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Steven C Bland
#1592, 21912 S Beaver Creek Rd, Oregon City, OR 97045

(1) Location of Well: NW 1/4 NW 1/4 Tax lot 00600 Section 06BB,
 Township 35. N, Range 1W. W, Washington County
 Address at well site: 24231 SW Middleton Rd, Sherwood, OR

(2) Start Card Number(s)(for work to be done): W212776


(3) Name and Address of Land Owner: Adam Cluff, 22808 SW
Hoster Way, Sherwood, OR 97140

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
80'

(5) The unusual site conditions which necessitate this request: Small property,
80' from neighbors drainfield

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
Based on wells in the area it is estimated
the seal hole will go to about 185'.
The seal material will be cement or bentonite.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Steve E. Bland

70. 0M1. 140 23 1XX2