



Oregon

John A. Kitzhaber, M.D., Governor

e✓
Water Resources Department

Commerce Building
158 12th Street NE
Salem, OR 97301-4172
(503) 378-3739
FAX (503) 378-8130

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of this order must be filed within the time specified by ORS 183.484 (2).

July 19, 2000

Dave Adamson
Adamson Pump and Drilling
1320 Smith Ave.
Nampa, ID 83651

Dear Dave:

Please find enclosed copies of the following approved special standards:

1. City of Vale (start card numbers 113190, 113191, and 113192)

If you have any questions concerning this letter, please contact me at the address or phone number listed above, or by e-mail at michael.l.mccord@ wrd.state.or.us.

Sincerely,

Michael L. McCord
Well Construction Specialist

c: Ron Jacobs, Dist. 9 Watermaster
Eastern Region Well Inspector



FINAL ORDER
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 6-21-00 Oral approval date (if applicable): 6-21-00 *Carrie Jones*

Bonded Well Constructor (name, license #, and mailing address): Adanson

Pump & Drilling # 1714 1320 Smith Ave
Nampa, Id 83651 208.466.6439

(1) Location of Well: SW 1/4 NE 1/4 of Section 31,
Township 18 N (S) Range 45 (E) W, Malheur County.
Address at well site: 3800 Airport Rd
Vale, Oregon

(2) Start Card Number(s): W113190, L23044

(3) Name and Address of Land Owner: City of Vale

252 B. Street W. Vale, Oregon 97918

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): _____

(5) The unusual conditions which necessitate this request: Requested well seal
shorten to 12' instead of 18' due to water supply
& depth of screen

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

RECEIVED

JUL 17 2000

W-55 ✓
WATER RESOURCES DEPT.
SALEM, OREGON

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

RECEIVED

JUL 17 2000

WATER RESOURCES DEPT.
SALEM, OREGON

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Dave Adamson

For Water Resources Department Use Only

Date: _____

Approved by: _____ Denied by: _____

Remarks: _____