

378-6207

ATT
MIKE MCCORD

FINAL ORDER
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 9-7-99 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): LARRY BURD

70732 S.W. Douglas Pendleton OR

(1) Location of Well: SE 1/4 SE 1/4 of Section 27,
Township 6 N/S. Range 34 E/W, Umatilla County.
Address at well site: Froyer Rd well #3

(2) Start Card Number(s): 118916 100744

(3) Name and Address of Land Owner: T.O. Williams & assoc

49654 Umapine Rd, Or. 97862

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): 200 YDS ^{Domestic}


(5) The unusual conditions which necessitate this request: well cased IN near
THE BOTTOM AT 560' TO 610'. USING 8" CASING

FROM 560' TO THE BOTTOM WOULD PRESERVE THE PUMP
CHAMBER AS WELL AS HOLD BACK THE CAUER AT 560 TO
(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

SET PER FORSTED PIPE FROM 550' TO 660'

W. CA

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Larry Burd

For Water Resources Department Use Only

Date: 9-9-99

Approved by: [Signature] Denied by: _____

Remarks: _____