



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1271
503-986-0900
FAX 503-986-0904

February 11, 2011

GARRY L ZOLLMAN #1881
ZOLLMAN'S LARRY BURD WELL DRILLING LLC
327 SE 1ST ST #145
PENDLETON OR 97801

FINAL ORDER


Dear Mr. Zollman:

The Special Standards Request Form you submitted for owner: Richard Funk, Start Card number 1012366, is hereby approved for the following: You may construct this eight-inch cased water well utilizing the under-reaming method as described on your Special Standards Request Form. The lower under-reamed drill hole shall extend at least fifteen feet into solid, uncreviced, consolidated rock overlying the water bearing rock formation. The lower grout seal shall be placed in accordance with method A, B or D as described in OAR 690-210-0150. Your Special Standards Request Form is enclosed. All other construction requirements must be adhered to. This special standard was verbally approved on January 25, 2011.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrdd.state.or.us.

Sincerely,



Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Scott White, Watermaster District 21
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

(Correction)
 (4)

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 01-26-2011 Oral approval date (if applicable): 01-26-2011

Bonded Well Constructor (name, license #, and mailing address): Garry Zollman OWRD #1881

Zollman's Larry Burd Well Drilling, LLC

(1) Location of Well: NW 1/4 Nw 1/4 Tax lot 100 Section 2
 Township 5 N, Range 35 E, Umatilla County

Address at well site: _____ Nearest address: 83651 Winesap Rd. Milton Freewater, OR

(2) Start Card Number(s)(for work to be done): 1012366

(3) Name and Address of Land Owner: Richard Funk

1979 JB George Rd. Walla Walla, WA 99362

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

100+

(5) The unusual site conditions which necessitate this request: To construct an 8" well using

underreamer system to seal 8" casing into Basalt formation. Overburden

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Seal at least 15' into basalt. Pressure cement grout into annular space.

RECEIVED

FEB 10 2011

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Harry J. Zollman

RECEIVED

FEB 10 2011

WATER RESOURCES DEPT
SALEM, OREGON