

RECEIVED P.2

SEP 27 2000

WATER RESOURCES DEPT.  
SALEM, OREGON

### FINAL ORDER Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 8/10/2000 Oral approval date (if applicable): 8/10/2000

Bonded Well Constructor (name, license #, and mailing address): CHRISTENSEN

Well Drilling Co. Paul Christensen, 33132 Coleman Rd, Eugene

(1) Location of Well: NW 1/4 SW 1/4 of Section 27

Township 17 N (S) Range 2 E (W) LANE County.

Address at well site: 1351 N 66<sup>TH</sup>  
Springfield, OR 97446

(2) Start Card Number(s): # 133501

(3) Name and Address of Land Owner: Springfield Utility Board  
202 S 18<sup>TH</sup> St, Springfield, OR 97477

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): ≈ 2000+

(5) The unusual conditions which necessitate this request: VOID AROUND  
SURFACE CASING TO ≈ 6 1/2'

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

LAYERS OF cement-concrete, Bentonite, AND  
fine crushed rock


W-5m

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

**RECEIVED**

SEP 27 2000

WATER RESOURCES DEPT  
SALEM, OREGON



**PLEASE NOTE:**

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature:

*Paul Christensen, V-Pres*  
*CHRISTENSEN WELL DRILLING CO.*

*For Water Resources Department Use Only*

Date:

*8-21-00*

Approved by:

*Michael McLeod*

Denied by:

Remarks: