

FINAL ORDER
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4/26/00 Oral approval date (if applicable): 4/25

Bonded Well Constructor (name, license #, and mailing address): Paul Christensen #636
Christensen Well Drilling Co.

33132 Coleman Rd., Eugene, OR 97408

(1) Location of Well: _____ 1/4 _____ 1/4 of Section 4,
Township 17 ~~(S)~~ Range 4 ~~(W)~~ Lane County.
Address at well site: 90201 Hwy 99 N
Eugene, OR

(2) Start Card Number(s): ~~121889~~ 121889

(3) Name and Address of Land Owner: Seneca Sawmill

90201 Hwy 99 N / PO Box 851, Eugene, OR 97440


(4) Distance to the nearest well, septic tank or drainfield (if water supply well): _____

(5) The unusual conditions which necessitate this request: place seal
down to water bearing formation (GRAVEL), without
losing grout into gravel.

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

place 10' of 3/4" Bentonite chips in bottom 10'
of seal area thru 12" surface casing as casing
is pulled back, Drive 8" casing thru chips to final depth
AND SEAL ABOVE chips AS PER CODE

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Paul Christensen

For Water Resources Department Use Only

Date: 4-26-00
 Approved by: Michael [Signature] Denied by: _____
 Remarks: _____