

STATE OF OREGON
WATER RESOURCES DEPARTMENT

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,
NE, Salem, OR 97310.

Date: MARCH 26, 1991

Well Constructor: CHRISTENSEN WELL DRILLING CO.
33132 COLEMAN RD. EUGENE, OREGON 97401

(1) Location of Well: SE 1/4 NE 1/4 of Section 23,
Township 18S, Range 12W, LANE County.

Address at well site or nearest known address: CITY OF FLORENCE FILTER
PLANT.

(2) Name and address of Landowner: CITY OF FLORENCE
P.O. BOX 340, 250 HWY 101 NORTH
FLORENCE, OREGON 97439

(3) The distance to the nearest well and septic drainfield: _____
NONE IN WELL FIELD AREA.


(4) The unusual conditions existing at the well site: _____
SAND DUNE WELL FIELD

(5) The proposed construction methods that the well constructor or landowner
constructing the well believes will be adequate for his particular well:
CONSTRUCTION OF WELL WITHOUT A SURFACE SEAL.

SC 25360

W-5m
remark: no seal

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



For Water Resources Department Use Only

Date:

3-26-91

Approved by:

[Signature]

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.