



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department

North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

November 2, 2010

JIM J HANSEN #1293
PERSON PUMP & WELL DRILLING
750 E BROADWAY ST
GOLDENDALE WA 98620-9242

FINAL ORDER

Dear Mr. Hansen:

The Special Standard request you submitted for owner: Chenowith Waters, Start Card number 1011810, is hereby approved for the following: You may abandon this water supply well in-place with cement grout as described on your Special Standards Request Form (See OAR 690-220-0030 and 690-220-0040). This is due to power lines being directly over the well, which prevented the drilling machine from being set up to perforate the casing. After abandonment the casing may be severed below land surface and removed. All other standards must be adhered to. Your Special Standards Request Form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.BYRD@wrdd.state.or.us.

Sincerely,

Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Scott White, Watermaster District 21
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 10/27/2010 **Oral approval date (if applicable):** 10/21/2010

Bonded Well Constructor (name, license #, and mailing address): Jim Hansen, #1293 80 MT. Adams hwy.

Trout lake wa. 98650

(1) Location of Well: sw 1/4 ne 1/4 Tax lot 6700 Section 30,
 Township 2 N, Range 13 E, Wasco County
 Address at well site: Chenowith Cr. Rd. & Maple St. The Dalles Or. 97508

RECEIVED

(2) Start Card Number(s)(for work to be done): 1011810

OCT 28 2010

(3) Name and Address of Land Owner: Chenowith waters

WATER RESOURCES DEPT
SALEM, OREGON

2312 W 8th. st. The Dalles or. 97508

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

200'

(5) The unusual site conditions which necessitate this request: Over head power lines directly over well

prevent drill rig set up to perforate 25' of 6" well casing

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Pressure grout from bottom (235') to surface, using cement grout, With out perforating casing.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

RECEIVED

OCT 28 2010

WATER RESOURCES DEPT
SALEM, OREGON

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Jim Han B. J. Han
1934