



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building

725 Summer St NE, Suite A

Salem, OR 97301

Phone (503) 986-0900

Fax (503) 986-0904

www.wrd.state.or.us

January 29, 2018

FLOYD SIPPEL WWC #1273
SIPPEL WELL DRILLING INC
7195 LAWRIDGE STREET NE
KEIZER, OREGON 97303

FINAL ORDER

Dear Mr. Sippel:

The Special Standards Request Form you submitted for owner: City of Woodburn, Start Card number 1037622, is hereby approved for the following: You may decommission this water supply well (MARI 1642) as outlined on your Special Standards Request Form. All other well decommissioning standards shall be adhered to. A copy of your Special Standards Request Form is enclosed.

Verbal approval of this Special Standards Request was provided on January 17, 2018.

If you have any questions regarding this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@oregon.gov.

Sincerely,

Joel Jeffery, Coordinator
Well Construction and Compliance Section

enclosure

cc: Barry Sanford, Well Inspector, Northwest Region
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards
Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 1-25-18 Oral approval date (if applicable): 1-17-18

Bonded Well Constructor (name, license #, and mailing address): Sippel Well Drilling Inc

1273 7195 Lawnridge St NE Keizer, Oregon 97303

(1) Location of Well: NE 1/4 SW 1/4 Tax lot 2800 Section 8, Township 5-S, Range 1-W, Marion County

Address at well site: 1750 Alexandra Ave Woodburn, Oregon 97071

(2) Start Card Number(s)(for work to be done): 1037622

(3) Name and Address of Land Owner: City of Woodburn 270 Montgomery St Woodburn, OR 97071

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well) 100ft +

(5) The unusual site conditions which necessitate this request: Loose silt formation behind 16" casing

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Abandon well in stages

RECEIVED
JAN 25 2018


OWRD

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

RECEIVED

JAN 25 2018

OWRD



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Floyd Sapp