

Oregon Water Resources Department OR: ORD278**REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240**

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 12/4/00 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Cascade Drilling Inc. - OR
6400 SE 101st Ave, Unit 2-D, Portland, OR 97266 Lic #: 10024

(1) Location of Well: NE 1/4 NE 1/4 of Section 19

Township 15 N/S, Range 2E E/W, Multnomah County.

Address at well site: SE 62nd Ave + SE Cooper St. Portland, OR
Brentwood Park

(2) Start Card Number(s): 136183

(3) Name and Address of Land Owner: City of Portland Bureau of
Environmental Services 1120 SW 5th Ave, Rm 1000
ATTN: Katie Thompson Portland, OR 97204-1917

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): unknown

(5) The unusual conditions which necessitate this request: 1' Pre sump at Bottom
of well for silts to settle. 2' concrete from 0-5' as

Requested By the City of Portland


(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

putting 14" 2' Below Bottom of screen instead of the
Reg. Required 1' concrete 0-5' instead of the normal
0-1' Monitoring wells - 4" diam PVC well screen & casing

Note: This order is a final order other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of this order must be filed within the time specified by ORS 183.484.

m-19

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

For Water Resources Department Use Only

Date: 2-16-01

Approved by: _____ Denied by: _____

Remarks: _____