



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building

725 Summer St NE, Suite A

Salem, OR 97301

Phone (503) 986-0900

Fax (503) 986-0904

www.wrd.state.or.us

JUNE 24, 2015

VANCE WAGNER WWC# 1738
TED PULLIAM WELL DRILLING
PO BOX 505
GRESHAM, OREGON 97030

FINAL ORDER

Dear Mr. Wagner:

The Special Standards Request Form you submitted for owner: Gordon Sester, Start Card number 201797, is hereby approved for the following: You may construct this water supply well within 94 feet from the nearest septic drain lines at the location shown on your site plan map and field verified by the Well Inspector for the Southwest Region. All other setback requirements must be met.

A condition of approval is that the well must be continuously cased and sealed to a minimum depth of 60 feet below land surface. A deeper seal will need to be placed if required by rule based on the formations encountered. A split seal is not allowed. This well may not commingle aquifers when completed. A copy of your Special Standards Request Form is enclosed. All other well construction standards must be adhered to.

Verbal approval of this Special Standards Request was provided on June 12, 2015.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@wrdd.state.or.us.

Sincerely,



Joel Jeffery, Coordinator

Well Construction Program

Oregon Water Resources Department

enclosure

cc: Barry Sanford, NW Region Well Inspector
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards

Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 6/12/15 Oral approval date (if applicable): 6/12/15

Bonded Well Constructor (name, license #, and mailing address): Vance Wagner
Lic # 1738 P.O. Box 505 Gresham, Or 97080

(1) Location of Well: SW 1/4 NE 1/4 Tax lot _____ Section 17,

Township 1S N/S, Range 4E E/W, Multnomah County

Address at well site: 31317 se Pipeline RD

Gresham, Or 97080

RECEIVED BY OWRD

JUN 19 2015

(2) Start Card Number(s)(for work to be done): _____ SALEM, OR

(3) Name and Address of Land Owner: Gordon Lester 33205
se Orlow Park RD Gresham, Or 97080

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

94 feet

(5) The unusual site conditions which necessitate this request: Drain Field

is 94 feet from Well site

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

seal a minimum of 60 feet into yellow
clay refer to existing well on property
mult 002540

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

RECEIVED BY OWRD

JUN 19 2015

SALEM, OR

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

