



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building

725 Summer St NE, Ste A

Salem, OR 97301

Phone: 503-986-0900

Fax: 503-986-0904

www.Oregon.gov/OWRD

March 20, 2019

MICHAEL MERRITT WWC #1879
M & M WELL DRILLING
5253 NE BLAKE COURT
ALBANY, OREGON 97321

FINAL ORDER

Dear Mr. Merritt:

The Special Standards Request Form you submitted for owner: Chris Lorenz, Pinot Gris Water Company, Start Card number: 1040513 is hereby approved for the following: You may decommission this water supply well as outlined on your Special Standards Request Form dated September 18, 2018. This Special Standards Request is due to you reporting, that the well screen was separated as you were removing the casing during the well Decommissioning. All other water well decommissioning standards shall apply. A copy of your Special Standards Request Form is attached.

Verbal authorization for this Special Standards Request was provided on September 18, 2018.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@oregon.gov.

Sincerely,

Joel Jeffery, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Barry Sanford, Well Inspector, Northwest Region
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 9-18-18 Oral approval date (if applicable): 9-18-18

Bonded Well Constructor (name, license #, and mailing address): M+M Well Drilling LLC
Mike Merritt 1879 5253 NE Blake Ct. Albany, OR 97321

(1) Location of Well: SW 1/4 NW 1/4 Tax lot _____ Section 18,

Township T11 S, Range 4 W Benton County

Address at well site: closest to 4635 NE Elliott Circle
Cornellis OR 97330

(2) Start Card Number(s)(for work to be done): 10,40513

(3) Name and Address of Land Owner: Pinet Gris Water Company
4941 Vinifera St. Cornellis OR 97330

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

long way N/A

(5) The unusual site conditions which necessitate this request: well went to pull

casing, casing pulled apart. Down the
hole.


(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

got the 8" casing out the 6" Liner + sand screen
came apart At 19 Feet. when this happen
called Joel he gave me Verbal OK.
to Abondment with chips.

RECEIVED

JAN 22 2019

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Mat Merritt

RECEIVED

JAN 22 2019

QWRD