



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building

725 Summer St NE, Ste A

Salem, OR 97301

Phone: 503-986-0900

Fax: 503-986-0904

www.Oregon.gov/OWRD

May 2, 2019

ROBERT STADELI WWC #1523
HOLT SERVICES INC.
PO BOX 1659
MILTON, WASHINGTON 98354

FINAL ORDER

Dear Mr. Stadel:

The Special Standards Request Form you submitted for owner: City of Milwaukie, Start Card number 1042619, is hereby approved for the following: You may construct this water supply well within 28 feet of an existing, buried storm water drain line. *A condition of approval of the Special Standards Request is that the well must be continuously cased and continuously sealed, with cement grout, to a minimum depth of 85 feet below land surface. A deeper seal will need to be placed if required by rule based on the formations encountered. A split seal is not allowed.* All other water supply well construction and abandonment standards shall apply. A copy of your Special Standards Request Form is enclosed.

Verbal approval of this Special Standards Request was provided on April 30, 2019.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well, constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@oregon.gov.

Sincerely,

Joel Jeffery, Coordinator
Well Construction Program
Well Construction and Compliance Section

Enclosure

cc: Barry Sanford, NW Region Well Inspector
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4-30-19 Oral approval date (if applicable): 4-30-19 9:30AM

Bonded Well Constructor (name, license #, and mailing address): Robert Stadeli

1523 PO Box 1659 Milton, WA 98354

(1) Location of Well: NE 1/4 SE 1/4 Tax lot _____ Section 25,
Township 1 N, Range 1 W, CLACKANAS County
Address at well site: 9951 SE 40th Ave
MILWAUKIE, OREGON

(2) Start Card Number(s)(for work to be done): 1042619

(3) Name and Address of Land Owner: CITY OF MILWAUKIE, OREGON
10722 SE MAIN ST. MILWAUKIE, OREGON 97222

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
STORM WATER DRAIN LINE 28 FT.

(5) The unusual site conditions which necessitate this request: Limited property available to
achieve standard set back requirements

(6) The proposed construction methods that the bonded well constructor believes will be
adequate for this well: (attach additional pages if needed)

See attached well diagram

RECEIVED

APR 30 2019

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____





RECEIVED

APR 30 2019

EXHIBIT A
Site Map and
Replacement Well Location
City of Milwaukee
Well 2 Replacement and
Well Decommissioning

LEGEND
 ○ Approximate Well Location
 □ Optional Discharge Point
 ~ Storm Man
 --- Drain from Reservoir
 --- Mainline Access
 --- To Lot



RECEIVED

APR 30 2019

OWRD

