



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building
725 Summer St. NE, Suite A
Salem, OR 97301
Phone 503-986-0900
FAX 503-986-0904
www.wrd.state.or.us

August 8, 2011

TERRY DAUGHERTY WWC 1505
RIVERSIDE INC
PO BOX 720
PARMA ID 83660

FINAL ORDER

Dear Terry:

The Special Standards Request Form you submitted for owner: Glen Teague, Start Card number 1008659, is hereby approved for the following: You may place unhydrated bentonite chips to a depth of 170 feet bgs in this well. All other standards must be adhered to. Your Special Standards Request Form is enclosed.

OAR 690-200-0021 requires the well constructor to request and receive approval prior to completion of the well. Please note, in the future, **no special standards will be granted for after-the-fact requests.**

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0852, or by e-mail at Juno.G.Pandian@wrd.state.or.us.

Sincerely,


Juno Pandian, Manager
Well Construction and Compliance Section

enclosure

cc: Bob Maynard, E Region Well Inspector
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 07/28/2011 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): _____

TERRY DAUGHERTY LIC#1505, P.O. BOX 720, PARMA, ID 83660

(1) Location of Well: NW 1/4 SE 1/4 Tax lot 5100 Section 17,
Township 21 S, Range 46 E, MALHEUR County
Address at well site: 1043 MENDIOLA ROAD, ADRIAN, OR 97901

(2) Start Card Number(s)(for work to be done): 1008659


(3) Name and Address of Land Owner: GLEN TEAGUE
1925 HWY 201 SOUTH, ADRIAN, OR 97901

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

(5) The unusual site conditions which necessitate this request: IN THIS AREA THE OPEN HOLE
STAYS OPEN EXTREMELY WELL, EXCELLANT LOCATION TO USE BENTONITE CHIPS.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
WILL RUN A 20" OPEN HOLE THEN DRY POUR 3/4" BENTONITE CHIPS FROM BOTTOM TO TOP.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: