



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building
725 Summer St. NE, Suite A
Salem, OR 97301
Phone 503-986-0900
FAX 503-986-0904
www.wrd.state.or.us

October 5, 2011

STEPHEN J SCHNEIDER #649
SCHNEIDER EQUIPMENT INC
21881 RIVER RD NE
ST PAUL OR 97137

FINAL ORDER

Dear Steve:

The Special Standards Request Form you submitted for owner: Joint Water Commission, Start Card number 201162, is hereby approved for the following: You may abandon the bottom of this well, from approximately 976 ft below ground surface (bgs) to above 933 ft bgs, as described on your Special Standards Request Form dated October 4, 2011. Your Special Standards Request Forms is enclosed. All other standards must be adhered to. This Special Standard was verbally approved on October 3, 2011.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.BYRD@ wrd.state.or.us.

Sincerely,


Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Bill Ferber, W Region Manager
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 10/4/11 Oral approval date (if applicable): 10/3/11

Bonded Well Constructor (name, license #, and mailing address): Steve Schneider, WWC 649

21881 River Road NE, St. Paul, OR 97137

(1) Location of Well: SW of 1/4 NW 1/4 Tax lot 1106 Section 25,
Township 1 S, Range 2 W, Washington County
Address at well site: 8655 SW Miller Hill Rd, Beaverton, OR

(2) Start Card Number(s)(for work to be done): 291162 201162


(3) Name and Address of Land Owner: Joint Water Commission
150 E. Main Street, Hillsboro, OR 97123

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
>100'

(5) The unusual site conditions which necessitate this request: Hole is for ASR. Drilled to 997'.
CRBG from 9' to 933'; sedimentary deposits (SD) from 933' to 997'. SD have caved more than once, currently
hole is at 976'. Want to decommission hole below the CRBG. Video shows no evidence of commingling from SD.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
Leave existing slough and pump neat cement grout from top of slough (~976') up to above 933'.
This will fill the voids from SD slough and provide a substantial plug to assure there can be no commingling from SD.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Stephen J. Schmidt

Kris Byrd

From: Steve Schneider [SteveS@seidc.com]
Sent: Wednesday, October 05, 2011 8:51 AM
To: Kris Byrd
Subject: Special Standard
Attachments: SCAN5693_000.pdf

Kris,
Attached is special standard request that was verbally approved late Monday. Do you want the original mailed to you?
Regards,

Steve Schneider
Vice President

Schneider Equipment, Inc.
also dba: Schneider Drilling Co.
21881 River Road NE
St. Paul, OR 97137
ph 503-633-2666
fx 503-633-2668

10/5/2011

Kris Byrd

From: Kris Byrd
Sent: Wednesday, October 05, 2011 9:17 AM
To: Steve Schneider
Subject: RE: Special Standard

Hi Steve,

I don't think it is necessary to send in the original. I'll work off of the scanned copy. Once I get your approved special standard written up, I'll e-mail you a copy and mail the original.

Regards,

Kris

Kristopher R. Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section
Oregon Water Resources Department
(503) 986-0851 Direct Line
(503) 986-0902 Fax
Were on the Web: www.wrd.state.or.us

From: Steve Schneider [mailto:SteveS@seidc.com]
Sent: Wednesday, October 05, 2011 8:51 AM
To: Kris Byrd
Subject: Special Standard

Kris,

Attached is special standard request that was verbally approved late Monday. Do you want the original mailed to you?

Regards,

Steve Schneider
Vice President

Schneider Equipment, Inc.
also dba: Schneider Drilling Co.
21881 River Road NE
St. Paul, OR 97137
ph 503-633-2666
fx 503-633-2668

10/5/2011