

July 17, 1997

RECEIVED

NOV 14 1997

WATER RESOURCES DEPT.
SALEM, OREGON

Oregon

WATER
RESOURCES
DEPARTMENT

Dave Storey
Storey Drilling Services
PO Box 98
Midland, OR 97634

Dear Dave:

Please find enclosed a copy of the following approved special standard:

1. Running Y Ranch Resort, Inc.

You are proposing to abandon the bottom portion of this well up to approximately 280 feet and have inquired as to the use of backfill material through this section. After review of the well report submitted by you upon original completion, I will allow the partial abandonment to occur as follows:

- 280-325 - Neat cement
- 325-645 - Clean backfill material (sand or gravel)

If you have any questions concerning this letter, please contact me at the address or phone number listed below.

Sincerely,



Rob Carter
Well Construction Specialist

cc: Larry Carey, Well Inspector

mswplss97@storey.2



Commerce Building
158 12th Street NE
Salem, OR 97310-0210
(503) 378-3739
FAX (503) 378-8130