



Oregon

John A. Kitzhaber, M.D., Governor

Water Resources Department

Commerce Building
158 12th Street NE
Salem, OR 97301-4172
(503) 378-3739
FAX (503) 378-8130

December 8, 2000

Gilbert Clayton
1951 Lambert Street
The Dalles, OR 97058

Dear Mr. Clayton:

Attached is a copy of the following approved special standard:

1. Orchard View Farms (start card number 52364)

This special standard is approved with the following conditions. *A WRD representative must be on site prior to any cement grout being placed in the well and the WRD representative shall inspect and approve of any grout that will be used in the well. Failure to comply with this condition will invalidate this special standard.* Without an approved special standard, this well will not meet minimum well construction standards. If this becomes the case, the well will have to be repaired to meet minimum standards or abandoned per WRD rules. If you have any questions concerning this letter, please contact me at the address or phone number listed above, or by e-mail at michael.l.mccord@wrд.state.or.us.

Sincerely,

Michael L. McCord
Well Construction Specialist

c: Brian Mayer NC Region Well Inspector
Larry Toll, District 3 Watermaster



RECEIVED

Oregon Water Resources Department

DEC 04 2000

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
WATER RESOURCES DEPT IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240
SALEM, OREGON

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: Dec. 1, 2000 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Gilbert Clayton

1951 Lambert St., The Dalles OR 97053, Lic #569

(1) Location of Well: SE 1/4 SW 1/4 of Section 29,
Township 1N N/S, Range 14E E/W, Wasco County.
Address at well site: 4335 Old Dufur Road, The Dalles OR 97058

(2) Start Card Number(s): W-52364

(3) Name and Address of Land Owner: Orchard View Farms, Inc. and
George R. & Lavelle Overman
4335 Old Dufur Road
The Dalles OR 97058

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): N/A

(5) The unusual conditions which necessitate this request: _____
Some leakage at bottom of 10" shoe according to video.
(see attached sheet)

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)
(see attached sheet)

Note: This order is a final order other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of this order must be filed within the time specified by ORS 183.484.

W-
remarks-repair / OT-

(7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: *Silbert Clayton*

For Water Resources Department Use Only

Date: 12-8-00

Approved by: Michael J. Milone Denied by: _____

Remarks: _____

St. @ 810 after plug set

This is attachment for Oregon Water Resources Department
Request for Written Approval dated December 1, 2000.

RECEIVED

DEC 04 2000

Start Card No. W-52364 Orchard View Farms, Inc.

**WATER RESOURCES DEPT.
SALEM, OREGON**

- (5) Nov. 16 & 17, 2000
I placed 6" wooden 6' plug from 975' to 981'. This shut off
enough water to lower water level from 548' to 310'
Nov. 29 & 30, 2000
Placed 9 7/8" wooden 5' plug from 965' to 970'. This should
be the best spot looking at the video.
- (6) When water level is below bottom of 10" shoe or 940' from
surface, I have a 14" dry wooden plug turned 10 1/8" o.d.
to fit the inside of 10" casing. I will set this plug with
2" galv pipe and this plug will have a cage with 2 1/2" hard ball
to make a check valve. This wooden plug will be set at
930' inside 10" casing. I will order 3 yds of groute (neet cement).