

STATE OF OREGON  
WATER RESOURCES DEPARTMENT

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT  
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS  
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,  
NE, Salem, OR 97310.

Date: 2-22-99

Well Constructor: LARRY BURD WELL DRILLING

(1) Location of Well: NE 1/4 SE 1/4 of Section 5,  
Township 1 N, Range 22E, GILLIAM County.  
Address at well site or nearest known address: 8 MI ROAD

(2) Name and address of Landowner: Bob PEPPERLING  
ARLINGTON  
OR

(3) The distance to the nearest well and septic drainfield: NA

(4) The unusual conditions existing at the well site: CLAY ZONE  
@ 1100 TO 1170


(5) The proposed construction methods that the well constructor or landowner  
constructing the well believes will be adequate for his particular well:

12" CASING w DRIVE SHOP ON BOTH ENDS  
TO BE INSTALLED FROM 1000' ± TO 1190 ±  
THIS LIVER WILL NOT TELESCOPE INTO THE PERMANENT  
CASING @ 496'

W-NA

SC 98348

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



(Signed) Jerry Burt  
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date: 2-22-99

Approved by: Michael J. Ladd

Denied by: \_\_\_\_\_

Remarks: \_\_\_\_\_  
\_\_\_\_\_

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.