



Oregon

John A. Kitzhaber, M.D., Governor

Water Resources Department

Commerce Building
158 12th Street NE
Salem, OR 97310-0210
(503) 378-3739
FAX (503) 378-8130

February 16, 2000

Patrick Wallace
Wallace Drilling
1707 S. W. 18th
Pendleton, OR 97801

Dear Pat:

Attached is a copy of the following approved special standard:

1. Western Heights Homeowners Association (start card number 119923)

Special standard requests must be submitted to the Department within (3) days from the date an oral approval is granted. Failure to do so in the future may result in the special standard being denied at a later date even if an oral approval was given. If a special standard request is denied, the Department will most likely require that any well that is not constructed to standard be abandoned. If you have any questions concerning this letter, please contact me at the address or phone number listed above, or by e-mail at michael.l.mccord@wrdd.state.or.us.

Sincerely,

Michael L. McCord
Well Construction Specialist

c: Carrie Jones, Eastern Region Well Inspector
Drillers File



Verbal approval by Mike McCord,
6-14-99.

Final Order
State of Oregon
Water Resources Department

RECEIVED

JAN 27 200

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHOD INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-206 WATER RESOURCES DEPT SALEM, OREGON

Before request can be considered, the following must be answered.

Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 158 12th Street NE, Salem, OR 97310. Requests may also be considered by the appropriate Regional Manager.

Date of request: 6-14-99

Bonded Well Constructor (or permitted land owner):

Petrick Wallace, Wallace Drilling

(1) Location of Well: SW 1/4 NE 1/4 of Section 13

Township 9S, Range 37E, Baker County.

Address at well site: _____

(2) Name and Address of Land Owner: _____

Western Heights Association

(3) The distance to the nearest well, septic tank or drainfield: _____

(4) The unusual conditions existing at the site: _____


(5) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed).

to set plug in 8"
casing and perforate 18" casing
above plug and pump cement
through perforations

WAS, OT
remarks seal method

- (6) Start Card #: 119923 (7) Diagram showing the pertinent features of the proposed well design and construction:

50
100
150
200



} perforations 170' to 190'
← plug

Signed: _____

(Bonded Constructor)

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the above signed shall return to the site and rectify the problem.

For Water Resources Department Use Only

Date:

2-16-00

Approved by:

Michael J. McCon

Denied by:

Remarks:

See Cover Letter

revised 9/1/93

NOTICE

This is a final order in other than a contested case proceeding. If you disagree with this order, you may file a petition for reconsideration of the order with the Water Resources Department. If no petition for reconsideration was filed with the agency, you may file a petition for review of the order with the Circuit Court for Marion County or the circuit court for the county in which you reside or do business. A petition for reconsideration or review must be filed within 60 days of the date the order was served. The petition should include the nature of your interest, the facts showing how you are adversely affected or aggrieved by the order and your reasons for reversing or remanding the order. When a petition for reconsideration is filed, the agency has 60 days to respond. If the agency takes no action, after 60 days the petition is deemed denied. You may petition the court for review of the order only within 60 days after agency action on a petition for reconsideration of the order or when the petition for reconsideration is deemed denied.