

Final Order

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 1 FEB 2000

Bonded Well Constructor (name, license and mailing address): RICHARD BECK

10300 SE CHAMPAIGN PORTLAND, OR 97266

(1) Location of Well: NW 1/4 NW 1/4 of Section 7, Township S 5,

Range 1 W, MARION County.

Address at well site: 1554 ASTOR WAY, WOODBURN

(2) Start Card Number(s): 119071

(3) Name and Address of Land Owner: CARL GERBERT

8230 S. GRIZZLY BEAR DR, CANBY, OR 97013

(4) The distance to the nearest well, septic tank or drainfield (if water supply well):

WELL ABANDONMENT

(5) The unusual conditions which necessitate this request: THE WELL IS

ABANDON WAS PACKED w/ GRAVEL.

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

PULL BACK THE 10" CASING UNTIL THE GRAVEL

STARTS TO CAVE, REMOVE GRAVEL, GRANT w/ CEMENT

BACK TO CASING, THEN REPEAT PROCESS UNTIL ALL GRAVEL IS REMOVED.

W-OP

- (7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):

ABANDON 10" IRRIGATION WELL

PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem. *THIS IS AN ABANDONMENT AND I WILL NOT RETURN TO THIS SITE. RB*
- (3) If verbal approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of verbal approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: *Robert Beck*

For Water Resources Department Use Only

Date: *2-2-00*

Approved by: *Michael [Signature]* Denied by: _____

Remarks: _____ revised: 4-96
