



# Oregon

Theodore R. Kulongoski, Governor

eV11-19-04

## Water Resources Department

North Mall Office Building  
725 Summer Street NE, Suite A  
Salem, OR 97301-1271  
503-986-0900  
FAX 503-986-0904

November 18, 2004

WILLOW CREEK IRRIGATION  
JON FIFE  
4732 JOHN DAY HWY  
VALE, OR 97918

### FINAL ORDER

Dear Mr. Fife:

The Special Standard request you submitted for owner: Bob Gressley, Start Card number 166992 is approved for the following: You may leave the existing 16 inch casing in place as you reseal the well from 75 feet below ground surface to land surface utilizing a 12 inch inner casing. See Oregon Administrative Rule (OAR) 690-210-0140 and 690-210-0230. Your Special Standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at [Kristopher.R.Byrd@wrdd.state.or.us](mailto:Kristopher.R.Byrd@wrdd.state.or.us).

Sincerely,

Kristopher Byrd  
Well Construction Program Coordinator  
Enforcement Section

enclosures

cc: Bob Maynard, Eastern Region Well Inspector  
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137.004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order.

RECEIVED

NOV 15 2004

Oregon Water Resources Department

WATER RESOURCES DEPT  
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 11-<sup>5</sup>~~0~~-04 Oral approval date (if applicable): \_\_\_\_\_

Bonded Well Constructor (name, license #, and mailing address): Jon Fife,

# 1485, 4732 Sunday Hwy Vale, OR 97918

(1) Location of Well: SW 1/4 SW 1/4 Tax lot 2401 Section 21,

Township 18S N, Range 46E W, Malheur County

Address at well site: Corner of Alameda + Onion Ave  
Ontario, OR

(2) Start Card Number(s)(for work to be done): 166992 / original 154995

(3) Name and Address of Land Owner: Bob Gressley 4010 Freese Lane  
Vale, OR 97918

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)  
\_\_\_\_\_

(5) The unusual site conditions which necessitate this request: would like to  
request leaving the 16" casing in this well  
as we were unable to pull the casing out.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

W  
OT

Remarks: Leave 16 inch casing in place

- (7) Diagram showing the pertinent features of the proposed well design and construction:  
(attach additional pages if needed)

**RECEIVED**

NOV 15 2004

WATER RESOURCES DEPT  
SALEM, OREGON

---

**PLEASE NOTE:**

- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

**I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.**

**Bonded Constructor Signature:** \_\_\_\_\_

*Jan M. Fife* # 1485

revised 11/03/2003