



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department

North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

July 7, 2010

ARTHUR L FRY #1355
FRY INDUSTRIES INC
PO BOX 135
SPRAGUE RIVER OR 97639

FINAL ORDER


Dear Art:

The Special Standard request you submitted for owner: Edward Stuedli, Start Card number 1010016, is hereby approved for the following: You may repair the unstable ground surrounding this well as described on your Special Standards Request form. The repair shall extend to a minimum depth of 15 feet bgs. All other standards must be adhered to. Your Special Standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.BYRD@wrp.state.or.us.

Sincerely,



Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Larry Carey, SC Region Well Inspector
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



RECEIVED

JUN 16 2010

Oregon Water Resources Department

WATER RESOURCES DEPT
SALEM, OREGON

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-2430. Requests may also be considered by the appropriate Regional Manager.

Date of request: 6-13-'10 Oral approval date (if applicable): 6-10-'10

Bonded Well Constructor (name, license #, and mailing address): ARTHUR L. FREY

LIC. #1355 PO BOX 135 SPRAGUE RIVER, OR 97639

(1) Location of Well: NE 1/4 SE 1/4 Tax lot 500 Section 06,

Township 40 N/S Range 10 E/W, KLAMATH County

Address at well site: 8441 DEHLINGER LN.

(2) Start Card Number(s)(for work to be done): 1010016

(3) Name and Address of Land Owner: EDWARD STUEDLI

8441 DEHLINGER LN KLAMATH FALLS, OR 97603

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

NONE WITHIN 1/4 MI.

(5) The unusual site conditions which necessitate this request: UNSTABLE GROUND


NEAR SURFACE (VERY SANDY WITH HIGH WATER TABLE)

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

INSTALL 18-20" X 250 X 24" CASING. CEMENT THE UNSTABLE

AREA TO DEPTH OF 15-18'

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Arthur L. Jay

revised 09/25/2003