



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department

North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

September 16, 2010

GARRY L ZOLLMAN #1881
ZOLLMAN'S LARRY BURD WELL DRILLING LLC
327 SE 1ST ST #145
PENDLETON OR 97801

FINAL ORDER


Dear Mr. Zollman:

The Special Standard request you submitted for owner: John Owen, Start Card number 1011322, is hereby approved for the following: After verifying that the well is clean to the natural bottom, you may abandon this water supply well as described on your Special Standards Request Form (enclosed). All other well abandonment standards must be adhered to. This special standard is required due to your inability to get your drilling machine over the well. A copy of your Special Standards Request Form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrд.state.or.us.

Sincerely,



Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Scott White, Watermaster District 21
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 9-2-10 Oral approval date (if applicable): 9-2-10

Bonded Well Constructor (name, license #, and mailing address): Garry Zollman, #1881

Zollman's Larry Burd Well Drilling, LLC 327 SE 1st St. #145, Pendleton, OR 97801

(1) Location of Well: NE 1/4 NW 1/4 Tax lot 1000 Section 7,
 Township 1 N, Range 31 E, Umatilla County
 Address at well site: 69167 Owen Ln., Pilot Rock, OR 97868

(2) Start Card Number(s)(for work to be done): 1011322

(3) Name and Address of Land Owner: John Owen P.O. Box E, Pilot Rock, OR 97868

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
100' +

(5) The unusual site conditions which necessitate this request: Inability to get drilling rig over well to pull casing or pour cement due to close proximaty of building.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
Abandon with Bentonite from bottom of well to 18' (bottom of casing) and cement from 18' to top of well.

RECEIVED

SEP 15 2010

WATER RESOURCES DEPT
 SALEM, OREGON

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

