



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building
725 Summer St. NE, Suite A
Salem, OR 97301
Phone 503-986-0900
FAX 503-986-0904
www.wrd.state.or.us

January 11, 2012

JONES DRILLING CO. INC.
BRET S JONES WWC 1684
29400 SANTIAM HWY
LEBANON, OR 97355

FINAL ORDER

Dear Bret:

The Special Standards Request Form you submitted for owner: City of Scotts Mills, Start Card number 1015730, is hereby approved for the following: You may abandon this gravel packed well utilizing the method described on your Special Standards Request Form (enclosed). All other standards must be adhered to.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.BYRD@wrdd.state.or.us.

Sincerely,

Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Bill Ferber, W Region Manager
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
725 Summer Street NE, Suite A
Salem Oregon 97301-1266
(503) 986-0900
www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 1/10/2012 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Bret Jones 29400 Santiam Hwy Lebanon Or 97355

(1) Location of Well: NW 1/4 NE 1/4 Tax lot 2300 Section 22,
Township 6 S, Range 1 E, Marion County
Address at well site: West end of 6th st

(2) Start Card Number(s)(for work to be done): 1015730

(3) Name and Address of Land Owner: City of Scotts Mills P. O. Box 220 Scotts Mills OR 97375

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
over 100'

(5) The unusual site conditions which necessitate this request: gravel pack

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

3/4 in Bentonite chips placed in well from 340' to 110' then pressure grout cement the rest of way up cut casing off at 2' below grade

RECEIVED

JAN 10 2012

WATER RESOURCES DEPT
SALEM, OREGON


- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____



Revised 7/26/2006

Special Standards Request Form /2

RECEIVED

JAN 10 2012

**WATER RESOURCES DEPT
SALEM, OREGON**

ENF