



Oregon

John A. Kitzhaber, MD, Governor

Water Resources Department

North Mall Office Building
725 Summer St. NE, Suite A
Salem, OR 97301
Phone 503-986-0900
FAX 503-986-0904
www.wrd.state.or.us

April 10, 2012

STEVEN N STADELI WWC 688
WESTERBERG DRILLING
36728 S KROPF RD
MOLALLA OR 97038

FINAL ORDER

Dear Steve:

The Special Standards Request Form you submitted for owner: Woodburn Nursery & Azaleas Incorporated, Start Card number 208145, is hereby approved for the following: You may abandon this gravel packed well and fill tube in-place with cement grout as described on your Special Standards Request Form. Your Special Standards Request Form is enclosed. All other standards must be adhered to.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrdd.state.or.us.

Sincerely,

Kristopher Byrd, Coordinator
Well Construction Program
Well Construction and Compliance Section

cc: Bill Ferber, W Region Manager
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4-6-12 Oral approval date (if applicable): 4-4-12

Bonded Well Constructor (name, license #, and mailing address): Steven Stadel

36728 S. Kropf Rd, Molalla, OR 97038 Lic#688

(1) Location of Well: NE 1/4 NE 1/4 Tax lot 600 Section 33,

Township 5S N, Range 1W W, Marion County

Address at well site: _____

13306 Monitor McKee Rd, Woodburn, OR 97071

(2) Start Card Number(s)(for work to be done): 208145 original well log MARI2042

(3) Name and Address of Land Owner: Woodburn Nursery & Azaleas Inc.

13009 Mckk School Rd, Woodburn, OR 97071

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

100+

(5) The unusual site conditions which necessitate this request: This is a gravel pack


well that has pumped lots of fine shallow sand over the years.

We recently had a drill rig working on this well and a sink hole appeared under the rig. The ground is to unstable to

(6) The proposed construction methods that the bonded well constructor believes will be jack up adequate for this well: (attach additional pages if needed) _____ out casing.

Perforate the 10" casing from top to bottom. Seal with cement grout under pressure to force grout out through the gravel pack. Clean out gravel inside of 6" gravel filler tube/casing
Perforate 6" gravel filler pipe and seal with cement grout.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Steven M. Staveli