



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building
725 Summer St NE, Ste A
Salem, OR 97301
Phone: 503-986-0900
Fax: 503-986-0904
www.Oregon.gov/OWRD

October 11, 2019

CLINTON S KINNEY WWC# 1753
CORVALLIS DRILLING COMPANY INC
3440 SE 3rd STREET
CORVALLIS, OREGON 97333

FINAL ORDER

Dear Mr. Kinney:

The Special Standards Request Form you submitted for owner: Michael Kaplenk, Start Card number 216306, is hereby approved for the following: You may decommission this water supply well as outlined on your Special Standards Request Form dated September 20, 2019. This approval is due to your reported fact that house has been built over the well. All other well decommissioning standards must be met. A copy of your Special Standards Request Form is enclosed.

Verbal approval of this Special Standards Request was provided on September 20, 2019.

If you have any questions regarding this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@oregon.gov.

Sincerely,

Joel Jeffery, Coordinator
Well Construction Program
Well Construction and Compliance Section

Enclosure

cc: Northwest Region
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 9-20-2019 Oral approval date (if applicable): 9-20-2019

Bonded Well Constructor (name, license #, and mailing address): (#1753)

Clinton Kinney 3440 SW 3rd Covallis, OR 97333

(1) Location of Well: SW 1/4 NE 1/4 Tax lot 2000 Section 19,
 Township 11 S, Range 4 W, Benton County
 Address at well site: 2720 NE Asbahr, Covallis, OR 97330

(2) Start Card Number(s)(for work to be done): 216306

(3) Name and Address of Land Owner: Michal Kaplan
2720 NE Asbahr, Covallis, OR 97330

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
60' 105' 25' under House

(5) The unusual site conditions which necessitate this request: House was Built over
{well}

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)
method C pump cement thru Tronite pipe

RECEIVED

SEP 30 2019

