



Oregon

Tina Kotek, Governor

Oregon Water Resources Dept

725 Summer St NE, Ste A Salem, OR 97301

Ph (503) 986-0900, Fax (503) 986-0904

www.oregon.gov/owrd

August 31, 2023

KRISS SCHNEIDER WWC/MWC #1578
SCHNEIDER WATER SERVICES
21881 RIVER RD NE
ST. PAUL, OR 97137

FINAL ORDER

Dear Mr. Schneider:

The Special Standards Request Form you submitted for owner: Rockwood PUD Jeremy Hudson, Start Card number 1071193; is hereby approved for the following: You may alter this water supply well (MULT 136199), by swaging the new 12-inch screen to the existing 16-inch liner, as described on your Special Standards Request Form dated August 31, 2023. All other well construction standards shall apply. A copy of your Special Standards Request Form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 302-8618, or by e-mail at tommy.k.laird@water.oregon.gov.

Sincerely,

Tommy Laird
Well Construction Program Coordinator
Oregon Water Resources Department

enclosure

cc: Ryan Pillsbury, Well Inspector, Northwest Region
Josh Lucas, Well Inspector, Northwest Region

This is a FINAL ORDER other than contested case. This final order is subject to judicial review under ORS 183.484. Any petition for judicial review of the final order must be filed within the time specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



Special Standards Request Form

Request for written approval to use construction methods not included in Oregon Administrative Rules 690-200 through 690-240.

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator. Requests may also be considered by the Well Construction Section Manager or Well Construction Compliance Coordinator.

Special Standard Nbr: 35140

Today's Date: 8/31/2023

Primary Startcard Nbr: 1071193

Status: REQUEST

Request Date: 8/30/2023

Driller Information

License Number: 1578 Phone Number: 503-633-2666
 Driller Name: KRISS SCHNEIDER
 Driller Company: SCHNEIDER WATER SERVICES
 Driller Address: 21881 RIVER RD NE, ST PAUL, OR 97137

Owner Information

Company: ROCKWOOD PUD
 First Name: JEREMY Last Name: HUDSON
 Street1: 19601 NE HALSEY ST.
 Street2:
 City: PORTLAND State: OR Zip: 97230
 Phone(Primary): Phone(Secondary):
 Email:

Type of Work

Fee Required: New No Fee Required: Alteration
 Conversion Abandonment
 Deepening Abandonment Method:

Original Start Card Original Well Label:
 Nbr:

Original Well Report: MULT 136199

Project Location

Street Address of Well: 710 NE 202ND. AVE. FAIRVIEW, OR 97024
 County: MULT Township: 1.00 N Range: 3.00 E Section: 33
 QQ/Q: SW / NW Latitude: 45.52830300 Longitude: -122.45442300
 Taxlot: 0900

Condition of Request

Type of Well: Water Well

The unusual conditions which necessitate this request: OTHER

The proposed construction methods that the well constructor believes will be adequate for this well: Repair of existing damaged relief screen by placing a smaller SS screen with SS blanks above and below then swage to the ID of the existing liner.

DEQ Site Or Facility ID:
Applies to monitoring wells only, if available.

List of Related Start Cards:

Start Card	Dist. to closed sewage/storm drain system	Dist. to Septic	Dist. to Drain Field	Meets Min Setback Req.	County Code	wl_nbr	Orig. well Log	Type of Well	TRSQQ	Tax Lot	Lat./Long.	Street Of Well
1071193				<input checked="" type="checkbox"/>			MULT 136199	W	1.00N3.00E33SWNW	0900	45.52830300 -122.45442300	710 NE 202ND. AVE. FAIRVIEW, OR 97024

Attachments:

Required Documents:

- Diagram and written description showing the pertinent features of the proposed well design, construction or abandonment. Include any setback constraints.

Title	Type	Summary
Location Drawing	DIAGRAM	Drawing of placement location
Location Drawing	DIAGRAM	Drawing of placement location

Note:

(1) The Well Construction Standards serve to protect ground water resources. By approving and issuing special construction standards, the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor or landowner is responsible for ensuring that a well is constructed in a manner that protects groundwater resources as required under Oregon Administrative Rules 690-200 through 690-240.

(2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.

(3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

