



Oregon

Theodore R. Kulongoski, Governor

EV
Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

March 31, 2006

HOLT DRILLING INC
WADE IVERSEN #1628
PO BOX 1890
MILTON, WA 98354

FINAL ORDER


Dear Mr. Iversen:

The Special Standard request you submitted for owner: City of Keizer, Start Card number 166123 is hereby approved for the following: You may remove your drilling machine off of the well site prior to completion of the work. This is due to a mechanical breakdown and the need to take your machine back to your shop for repair. The condition is that a new drilling machine must be back on site no later than April 3, 2006. Prior to removing your drilling machine from the site the well shall be properly covered and protected from damage and/ or vandalism. Your Special Standard request is enclosed for your information.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard, the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor and/or landowner is responsible for ensuring that a well constructed in a manner that protects the ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrdd.state.or.us.

Sincerely,



Kristopher Byrd
Well Construction Program Coordinator
Enforcement Section

enclosure

cc: Joel Jeffery, NW Region Well Inspector
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.

S.C. 166123

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 3-31-06 Oral approval date (if applicable): 3-31-06 KB

Bonded Well Constructor (name, license #, and mailing address): Jim Niederkorn
#1829 / WAC Iverson #1628

(1) Location of Well: NW 1/4 NW 1/4 Tax lot _____ Section 2,
 Township 7S N, Range 3 (W), _____ County
 Address at well site: 4969 RICKMAN RD KEIZER OR

(2) Start Card Number(s)(for work to be done): 166123

(3) Name and Address of Land Owner: CITY OF KEIZER

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

(5) The unusual site conditions which necessitate this request: _____

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

W
DR
Remarks: moving off site 3/31/06 Through 4/3/06

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

Rig broke down pulled off well, will be replaced
with another rig on 4-3-06

PLEASE NOTE:

- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

[Handwritten Signature]

1829