



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

November 3, 2005

GEO TECH EXPLORATIONS
GREG MCINNIS #1464
19700 SW TETON
TUALATIN OR 97062

FINAL ORDER


Dear Greg:

The Special Standard request you submitted for owner: Chemical Waste Management of the NW, Start Card number 180971, is hereby approved for the following: You may install a liner in this well that overlaps the permanent casing four feet instead of the required eight feet (See OAR 690-210-0290). All other well construction standards must be adhered to.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrdd.state.or.us.

Sincerely,


Kristopher Byrd
Well Construction Program Coordinator
Enforcement Section

enclosure

cc: Brian Mayer, NC Region Well Inspector
File

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 11/2/05 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Greg McInnis

1464 / 19700 SW Teton Ave., Tualatin, OR 97062

(1) Location of Well: NW 1/4 NE 1/4 Tax lot 1101 Section 31,
Township 2 N, Range 21 E, Gilliam County

Address at well site: 17629 Cedar Springs Lane
Arlington, OR

(2) Start Card Number(s)(for work to be done) 18071 180971

(3) Name and Address of Land Owner: Chemical Waste Management of the NW
17629 Cedar Springs Lane, Arlington, OR 97812

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
N/A

(5) The unusual site conditions which necessitate this request: 12" production
set to 250'. Need to maximize available drawdown by setting the pump as deep
as possible in the 12" pump chamber.

(6) The proposed construction methods that the bonded well constructor believes will be
adequate for this well: (attach additional pages if needed)
Shorten the required 8- foot overlap to 4- foot overlap.

W
OT
REMARKS: Liner over laps casing 4 feet.

