



Oregon

Kate Brown, Governor

Water Resources Department

North Mall Office Building
725 Summer St NE, Suite A
Salem, OR 97301
Phone (503) 986-0900
Fax (503) 986-0904
www.wrd.state.or.us

August 31, 2018

AARON ADAMS WWC #10576
YELLOW JACKET DRILLING
16765 SE 362ND DRIVE
SANDY, OREGON 97055

FINAL ORDER

Dear Mr. Adams:

The Special Standards Request Form you submitted for owner: City of Merrill, Start Card number 1039334, is hereby approved for the following: you may decommission this water supply well as outlined on your Special Standards Request Form dated July 30, 2018. A copy of your Special Standards Request Form is enclosed.

Verbal approval of this Special Standards Request was provided on July 24, 2018.

This Special Standards Request approval is a modification of the Special Standards Request approval issued to you on July 3, 2018 for the same Start Card number. If you have any questions concerning this letter, I may be contacted at (503) 986-0852, or by e-mail at Joel.W.Jeffery@oregon.gov.

Sincerely,

Joel Jeffery, Coordinator
Well Construction Program
Well Construction and Compliance Section

enclosure

cc: Southwest Region
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.





Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 7/30/18 Oral approval date (if applicable): 7/24/18

Bonded Well Constructor (name, license #, and mailing address): Aaron Adams, 10576

16765 SE 362nd Drive, Sandy, OR 97055

(1) Location of Well: NE 1/4 NE 1/4 Tax lot 01000 Section 11,
 Township 41 S, Range 10 E, Klamath County
 Address at well site: 137 W. Front Street, Merrill, OR 97633

(2) Start Card Number(s)(for work to be done): 1039334

(3) Name and Address of Land Owner: City of Merrill, 301 Second St, Merrill, OR 97633

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
>50 feet

(5) The unusual site conditions which necessitate this request: A 10 inch cable tool drill bit
was lost in hole on construction in 1962 at 932 feet below ground surface

Existing well KLAM 14959

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Use of clean disinfected gravel at bottom of well, a bentonite plug, then a 75' lift

of cement grout to seal off bottom of well

(see attached proposed well abandonment diagram)

RECEIVED

JUL 30 2018

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

SEE attached

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.


I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____




WELL KLAM 14959

NOTE:
 CUT CASING A MINIMUM OF 30" BELOW
 EXISTING GROUND SURFACE PRIOR TO
 CONCRETE PAD PLACEMENT




NOTE:
 WELL ABANDONMENT
 VARIANCE REQUIRED FROM
 WATER RESOURCES FOR
 GRAVEL DEPTH
 BOTTOM OF WELL



PROPOSED WELL ABANDONMENT

SCALE: NTS

SHEET 3 OF 3 FILE WELL	DATE: FEB 2018 SCALE: NO SCALE JOB: 2017-122 DWN: BT, JEH	PROPOSED WELL ABANDONMENT CITY OF MERRILL MUNICIPAL WATER SUPPLY WELL
---------------------------	--	--



**ANDERSON ENGINEERING
 AND SURVEYING, INC.**

P.O. BOX 28
 LAKEVIEW, OREGON 97830
 (541) 847-4407 FAX 847-2321
 WWW.ANDERSONENGINEERING.COM