



Oregon

Tina Kotek, Governor

Oregon Water Resources Dept

725 Summer St NE, Ste A Salem, OR 97301

Ph (503) 986-0900, Fax (503) 986-0904

www.oregon.gov/owrd

May 1, 2024

BRANDON BROWN WWC #1766
WATER WELL DEVELOPING AND SURVEYS
P.O. BOX 156
UMATILLA, OR 97882

FINAL ORDER

Dear Mr. Brown:

The after-the-fact Special Standards Request Form you submitted for owner: Arn, LLC, Start Card number: 1072076, is hereby approved for the following: You may construct this water supply well as described on your Special Standards Request Form dated April 29, 2024, with a couple of stipulations as described below:

-The upper seal may be placed according to Oregon Administrative Rule (OAR) 690-210-0130. The upper bentonite seal shall extend from land surface to a depth of 18 ft bgs.

-The lower split seal shall be placed according to OAR 690-210-0150 (1)(c) Method 3 (Under-Reaming). The lower cement seal shall extend from 152 ft bgs to 169 ft bgs.


All other well construction standards apply as required under Oregon Administrative Rules 690-210. A copy of your Special Standards Request Form is enclosed.

OAR 690-200-0021 requires the well constructor to request and receive Special Standards approval prior to completion of the well. Please note, in the future, **no Special Standards will be granted for after-the fact request.**

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 991-2470, or by e-mail at Kristopher.R.Byrd@water.oregon.gov.

Sincerely,



Kristopher R. Byrd, Manager
Well Construction Section

Enclosure

cc: Tommy Laird, Well Construction
Shaun Finn, Well Inspector, Northcentral Region

This is a FINAL ORDER other than contested case. This final order is subject to judicial review under ORS 183.484. Any petition for judicial review of the final order must be filed within the time specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4/29/24 **Oral approval date (if applicable):** _____

Bonded Well Constructor (name, license #, and mailing address): _____

Brandon Brown, 1766, PO BOX 156 Umatilla, OR 97882

(1) Location of Well: NW 1/4 NE 1/4 Tax lot 304 Section 34,
 Township 5 N, Range 28 W, Umatilla County
 Address at well site: 30980 Baggett Ln, Hermiston, OR 97882

(2) Start Card Number(s)(for work to be done): 1072076

(3) Name and Address of Land Owner: ARN, LLC 36 EAGLE CREST DR
UNION GAP WA 98903

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

(5) The unusual site conditions which necessitate this request: _____

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Split seal on 8" casing. Hydraulically, the resource will be protected with surface seal, and having sealed into consolidated basalt formation.

Mitsubishi shoed underreaming device. 10" cut.

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Brandon Brown