

### Oregon Water Resources Department

#### REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 5-15-02 Oral approval date (if applicable): 5-14-02

Bonded Well Constructor (name, license #, and mailing address): Greg McInnis #1464  
19700 SW Teton Trvalatin OR 97062

(1) Location of Well: NE 1/4 NE 1/4 of Section 29  
Township 6 N S, Range 34 E W, \_\_\_\_\_ County.  
Address at well site: 2 mi west of Umapine Hwy on  
Troyer Rd

(2) Start Card Number(s): 149726

(3) Name and Address of Land Owner: White Bros % Carol White Kirkman  
304 N Ninth AVE Walla Walla, WA 99362

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): More than 200'

(5) The unusual conditions which necessitate this request: the need to  
install a reduced annulus seal at the  
basalt contact at 848 - 878'


(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)  
Pressure Grout Cement from inside out to  
force cement into reduced annulus. Grout  
will be tremied to bottom of hole

Note: This order is a final order other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of this order must be filed within the time specified by ORS 183.484.

W-25

**RECEIVED**  
MAY 15 2002  
WATER RESOURCES DEPT  
SALEM, OREGON

(7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed)



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: *[Handwritten Signature]*

*For Water Resources Department Use Only*

Date: 5-16-02

Approved by: *Jacy Echenlaub* Denied by:

Remarks: