



# Oregon

Tina Kotek, Governor

**Oregon Water Resources Dept**  
725 Summer St NE, Ste A Salem, OR 97301  
Ph (503) 986-0900, Fax (503) 986-0904  
[www.oregon.gov/owrd](http://www.oregon.gov/owrd)

December 20, 2024

JIM MACK SR WWC/MWC #1493  
BANDON WELL AND PUMP CO  
47530 HWY 101  
BANDON, OR 97411

## FINAL ORDER

Dear Mr. Mack:

The Special Standards Request Form you submitted for owner: Elk River Property Development, Start Card number 1076288, is hereby approved for the following: You may alter this water supply well (CURR 53312) as described on your Special Standards Request Form dated December 20, 2024. with a couple of stipulations as described below:

- ***The Sch80 PVC casing shall conform to ASTM D1785 and meet the standards of the National Sanitation Foundation.***
- ***The Sch80 PVC casing shall not extend beyond a depth of 200 feet.***
- ***The Sch80 PVC casing shall not be used in the annular seal interval.***

All other well construction standards apply as required under Oregon Administrative Rules 690-210. A copy of your Special Standards Request Form is enclosed.

Verbal approval of this Special Standards Request was provided on December 20, 2024.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions regarding this letter, I may be contacted at (503) 302-8618, or by e-mail at [tommy.k.laird@water.oregon.gov](mailto:tommy.k.laird@water.oregon.gov).

Sincerely,

Tommy Laird  
Well Construction Program Coordinator  
Well Construction Section

Enclosure

cc: Joseph Wallner-Sentle, Southwest Region Well Inspector

**This is a FINAL ORDER other than contested case. This final order is subject to judicial review under ORS 183.484. Any petition for judicial review of the final order must be filed within the time specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.**



Oregon Water Resources Department  
 725 Summer Street NE, Suite A  
 Salem, OR 97301-1266  
 (503) 986-0900  
 (503) 986-0902 Fax  
[wrd\\_dl\\_wcc@water.oregon.gov](mailto:wrd_dl_wcc@water.oregon.gov)

# Special Standards Request Form

## REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Program Coordinator, Water Resources Department, 725 Summer Street NE, Suite A, Salem, OR 97301-1266. Requests may also be considered by the Well Construction Section Manager or Well Construction Compliance Coordinator.

Date of request: 12/20/24 Oral approval date (if applicable): \_\_\_\_\_

Bonded Well Constructor (name, license #, and mailing address): Jim Mack Sr

WRD 1493 47530 Hwy 101 Bandon, OR 97411

(1) Location of Well: SE  $\frac{1}{4}$  NE  $\frac{1}{4}$  Tax Lot: 4400 Section: 30

Township: 32 S Range: 15 W County: Curry

Latitude: 42.77746882 Longitude: -124.51338415

(2) Special Standards Number (OWRD Assigned): \_\_\_\_\_

(3) Start Card Number(s) (for work to be done): 107B288

(4) Well Label Identification Number (if assigned): L116515

(5) Associated Well Report Numbers (if applicable): \_\_\_\_\_

(6) Name and Address of Landowner: EIK River Property Development

P.O. Box 790 Port Orford, OR 97465

(7) Address of Project/Well Site: Next to 92361 Knapp Rd. Port Orford

(8) Type of Work (New, Deepening, Alteration, Abandonment): \_\_\_\_\_

(9) Distance to Nearest Septic Tank, Drain Field, Closed Sewage Line, and Closed Storm

Drainage System (if water supply well): 100' +

(10) The Unusual Site Conditions Which Necessitate this Request: 6" PVC Cased Well

Drilled to 178' w/20' of 6" stainless steel screen from  
140'-150', 155'-160', 165'-170', TD 178'

(11) The Proposed Construction Methods the Bonded Well Constructor Believes will be

Adequate for this Well (attach additional pages if needed): Set 6" SDR 21

0-140', Sch 80 PVC 150-155, 160-165, 170-178 (Tail Pipe

(12) Attach a Site Map Showing the Relationship of the Well(s) to Any Existing Septic Tank, Drainfield, Closed Sewage Line, and Closed Storm Drainage System if the Request is to Place a Water Supply Well Within the Minimum Setbacks Detailed in OAR 690-210-0030.

(13) If the Request is to Abandon a Monitoring Well In-Place, Then the Most Current Water Quality Analytical Data Must be Provided.

(14) Monitoring Well Special Standard Requests Must Provide Oregon Department of Environmental Quality Site or Facility Identification Number and No Further Action (NFA) Decision (if applicable).

(15) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if need):


SEE Attached Drawing

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing special construction standards, the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor or landowner is responsible for ensuring that a well is constructed in a manner that protects groundwater resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.



Bonded Constructor Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to read "Jim Mack Sr.", is written over a horizontal line. The signature is cursive and extends slightly above and below the line.

6" P.S. screen  
+ 6" cent. lock

Pacific Gates  
L116515  
west

Sch 80



10  
20  
30  
40  
50  
60  
70  
80  
90  
100  
110  
120  
130  
140  
150  
160  
170  
180  
190  
200  
210  
220  
230  
240

10' .070 WHITE  
5' - .070 WHITE  
5' - .070 WHITE  
6/9 Sand Pack

140  
150  
160  
170  
180  
190  
200  
210  
220  
230  
240

10' .070 6"  
4' Blank  
5' .070 6"  
5' .070 6"  
SOLID  
FD