

STATE OF OREGON  
WATER RESOURCES DEPARTMENT

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT  
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS  
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road,  
NE, Salem, OR 97310.

Date:

11/14/95

Well Constructor:

Mack Drilling Co. Inc.

1345 20th Str. SE Salem, OR  
97302

(1) Location of Well: NW 1/4 SW 1/4 of Section 34,

Township 2S, Range 1W, Washington County.

Address at well site or nearest known address: 11911 SW Walden  
Sherwood, OR 97140

(2) Name and address of Landowner:

Morse Bros.

32260 Hwy 34

Tangent, OR 97389

(3) The distance to the nearest well and septic drainfield: Over 170 feet

(4) The unusual conditions existing at the well site: Owner installed  
fence on easement & blocking access to monitoring  
with vehicles other than off road equipment.

(5) The proposed construction methods that the well constructor or landowner  
constructing the well believes will be adequate for his particular well:

Install 4 concrete blocks around the  
well for protection. Blocks measure 3'x3'  
instead of pipe ballards.

M-OT  
remark: protection

L1/14/95

13:22

503 375 0961

MACK DRILLING

003/003

- (6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):

(Signed)

*Eugene H. Mack*  
(WELL CONSTRUCTOR)

For Water Resources Department Use Only

Date:

1-17-96

Approved by:

*R. H. L. A.*

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.