



# Oregon

Theodore R. Kulongoski, Governor

**Water Resources Department**

North Mall Office Building  
725 Summer Street NE, Suite A  
Salem, OR 97301-1266  
503-986-0900  
FAX 503-986-0904

October 30, 2007

JONES DRILLING CO. INC.  
BRET S JONES WWC 1684  
29404 SANTIAM HWY  
LEBANON, OR 97355

## FINAL ORDER


Dear Bret:

The Special Standard request you submitted for owner: Bill Sable, Start Card numbers 195524, 197190 and 197191 is hereby approved for the following: After removing any debris from the wells you may abandon them in place with unhydrated bentonite chips. The well casings to be abandoned may be severed below land surface and removed. These wells are in a vault six feet below land surface and it would be unsafe to abandon them with a drilling machine. All other well construction requirements apply. Your Special Standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at [Kristopher.R.Byrd@ wrd.state.or.us](mailto:Kristopher.R.Byrd@ wrd.state.or.us).

Sincerely,



Kristopher Byrd  
Well Construction Program Coordinator  
Well Construction and Compliance Section

enclosure

cc: Joel Jeffery, NW Region Well Inspector  
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



### Oregon Water Resources Department

#### REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 10-29-07 Oral approval date (if applicable): 10-29-07

Bonded Well Constructor (name, license #, and mailing address): Bret Jones

1684 29404 Santiam Hwy Lebanon OR

(1) Location of Well: \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 Tax lot 1500 Section 4

Township 10S , Range 3 W , Linn County

Address at well site: 33565 Dover connet

(2) Start Card Number(s)(for work to be done): 195524, 197190, 197191

(3) Name and Address of Land Owner: <sup>contact</sup> Bill Seble 503-572-5831

Baris Griggle same 33565 Dover connet

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

over 100'

(5) The unusual site conditions which necessitate this request: old well

in pit below ground not safe

Access for Newer equipment

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Fill w Bentonite

#1 8" well 22' deep

Approx 6' Below ground

#2 8" well 20' deep

#3 8" well 17' deep

RECEIVED

OCT 29 2007

WATER RESOURCES DEPT  
SALEM, OREGON

- (7) Diagram showing the pertinent features of the proposed well design and construction:  
(attach additional pages if needed)

---

**PLEASE NOTE:**

- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

**I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.**

**Bonded Constructor Signature:** 

revised 11/03/2003

**RECEIVED**

OCT 29 2007

WATER RESOURCES DEPT  
SALEM, OREGON