



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

October 3, 2006

PERSON PUMP & WELL DRILLING
JIM J HANSEN #1293
166 RIMROCK RD
GOLDENDALE, WA 98620

FINAL ORDER

Dear Mr. Hansen:

The Special Standard request you submitted for owner: City of Mosier, Start Card number 175038, is hereby approved for the following: You may leave approximately 9.5 ft of 20 inch oversize casing in this well. The oversize casing was inadvertently grouted in place and you are not able to remove it. All other well construction requirements apply. If in the future this well is found to be commingling, causing a loss of artesian pressure or is a health hazard or health threat then you will be required to return to the well for repair or abandonment. Your Special Standard request form is enclosed.

OAR 690-240-0006 requires the well constructor to request and receive approval prior to completion of the well. Please note, in the future, no special standards will be granted for after-the-fact requests.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard, the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor and/or landowner is responsible for ensuring that a well constructed in a manner that protects the ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, I may be contacted at (503) 986-0852 or by e-mail at: Juno.G.Pandian@ wrd.state.or.us.

Sincerely,

JUNO PANDIAN, Manager
Enforcement Section

enclosure

cc: Kris Byrd, Well Construction Program Coordinator
Brian Mayer, NC Region Well Inspector

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied.



Oregon Water Resources Department
 725 Summer Street NE, Suite A
 Salem Oregon 97301-1266
 (503) 986-0900
 www.wrd.state.or.us

Special Standards Request Form

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite A, Salem OR 97301-1266. Requests may also be considered by the appropriate Regional Manager.

Date of request: 09/27/2006 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): Jim Hansen 1293

166 Rimrock Road, Goldendale, WA 98620

(1) Location of Well: NE 1/4 NE 1/4 Tax lot 400 Section 12,

Township 2 N, Range 11 E, Wasco County

Address at well site: 951 Mosier Creek Road, Mosier OR

(2) Start Card Number(s)(for work to be done): 175038

(3) Name and Address of Land Owner: City of Mosier

Mosier, OR

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

N/A

(5) The unusual site conditions which necessitate this request: _____

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

9' 5" of 20" pipe was left in the hole as it was inadvertently cemented in.

*W
OT
Remarks: 9.5 ft of oversize casing grouted in hole*

RECEIVED

OCT 02 2006

WATER RESOURCES DEPT
SALEM, OREGON

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Jim Hansen

