

e✓ 11-27-02

Tracy

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: Nov. 22, 2002 Oral approval date (if applicable): Nov. 18, 2002

Bonded Well Constructor (name, license #, and mailing address): Michael Waldrop

1810 LANA AVE. NE SALEM, 97303

(1) Location of Well #3- NW SW #4- SE 1/4 NW 1/4 of Section 25

Township 4 N (S) Range 4 E (W) Yamhill County.

Address at well site: no address, across Airport Rd from McMinnville Airport

(2) Start Card Number(s): 141233 & 141232

(3) Name and Address of Land Owner: Cities of Dayton-Lafayette Oregon Dayton City Hall - 416 Ferry St., Dayton Ore. 97114

(4) Distance to the nearest well, septic tank or drainfield (if water supply well): NONE

(5) The unusual conditions which necessitate this request: installation of a 10" weld-on pitless adapter necessitated a large pit around the casing to 5' BGL.


(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

setting of a heavy cardboard cement-type form, 24" i.d., over the pitless & conduits, backfilling around the form with dirt & inside the form w/dry bentonite, leaving the form in the ground.

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the time specified by ORS 183.484(2).

W-OT

(7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Michael Waldrop

For Water Resources Department Use Only

Date: 11/26/02
Approved by: David Jandt Denied by: _____
Remarks: Verbal approval given previously.