

ew
Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 3/23/99

Bonded Well Constructor (name, license and mailing address): Steve Schneider
WWC 649 21881 River Rd NE St. Paul, OR 97137

(1) Location of Well: SE 1/4 NE 1/4 of Section 28, Township 1S,
Range 4E, Clackamas County.

Address at well site: nearest is 34210 Bluff Rd -
well is ~ 800' west

(2) Start Card Number(s): 118723

(3) Name and Address of Land Owner: J Franks Schmidt & son Co.
P.O. Box 189, Boring, OR 97009

(4) The distance to the nearest well, septic tank or drainfield (if water supply well): over
100'


(5) The unusual conditions which necessitate this request: cascading water

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)

Shale trap @ 280'± & extend inner casing
to above 180'. see (?)

w-ot
remark-repair

(7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If verbal approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of verbal approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

For Water Resources Department Use Only

Date: 3.23.99

Approved by: Michael J. Long Denied by: _____

Remarks: _____ revised: 4-96