



Oregon

Theodore R. Kulongoski, Governor

Water Resources Department

North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1266
503-986-0900
FAX 503-986-0904

September 28, 2006

Wallowa County Health Care District
Attn: Daniel McCarthy
401 NE 1st
Enterprise, OR 97828

FINAL ORDER


Dear Mr. McCarthy:

This Final Order will confirm the construction details we spoke about today relating to your wells. The Special Standard requests you submitted for three wells you are constructing under Landowner Permits dated September 29, 2006: Start Card numbers 190902 (Well1), 190903 (Well2) and 190904 (Well3), are hereby approved for the following: The wells shall be approximately 20 feet deep and shall have a minimum ten (10) foot surface seal (See Oregon Administrative Rule (OAR) 690-210-0400). Also, the top terminal height of each well shall be a minimum of 12 inches above the finished ground surface or pump house floor and a minimum of 12 inches above the local surface runoff level (See OAR 690-210-0250). If the wells are flowing at land surface then they shall be completed to the standards outlined in OAR 690-210-0155. All other construction standards must be adhered to. Your Special Standard request forms are enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at Kristopher.R.Byrd@wrđ.state.or.us.

Sincerely,


Kristopher Byrd
Well Construction Program Coordinator
Enforcement Section

enclosure

cc: Bob Maynard, E Region Well Inspector
File

This is a final order in other than contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137-004-0080 you may either petition for judicial review or petition the Director for reconsideration of this order. A petition for reconsideration may be granted or denied by the Director, and if no action is taken within 60 days following the date the petition was filed, the petition shall be deemed denied. ♻️