

FINAL ORDER Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before request can be considered, the following must be answered. Requests shall be submitted to the Well Construction Specialist, Water Resources Department. Requests may also be considered by the appropriate Regional Manager.

Date of request: 11-8-00 Oral approval date (if applicable): 10-23-00

Bonded Well Constructor (name, license #, and mailing address): G.M. Innis, 14604

19700 SW Teton Ave, Tualatin, OR 97062

(1) Location of Well: _____ 1/4 _____ 1/4 of Section _____,
Township _____ N/S, Range _____ E/W, _____ County.
Address at well site: See attached sheet

(2) Start Card Number(s): 129529 - 132966 - 132773

(3) Name and Address of Land Owner: City of Portland 1120 SW 5th
Avenue, Rm 825 Portland OR 97204


(4) Distance to the nearest well, septic tank or drainfield (if water supply well): approx 200'

(5) The unusual conditions which necessitate this request: City of Portland is
Constructing well houses over the well head &
will need to excavate down approx 5' below ground

(6) The proposed construction methods that the well constructor believes will be adequate for this well (attach additional pages if needed)
to leave Sanitary Ground Seal at approx 5'
below ground surface so building contractor
will not disturb Sanitary Seal & finished casing
will terminate just above finished floor inside well house

W-OT
remark: seal to grade

(7) Diagram showing the pertinent features of the proposed well design and construction (attach additional pages if needed):



PLEASE NOTE:

- (1) If approved, all other phases of well construction must comply with the appropriate standards described in OAR 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing groundwater contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Greg McBurnis

For Water Resources Department Use Only

Date: 11.8.00

Approved by: Michael L. McLeod Denied by: _____

Remarks: _____