

STATE OF OREGON
WATER RESOURCES DEPARTMENT

ew

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road, NE, Salem, OR 97310.

Date: 4/9/92

Well Constructor: STACO Well Services
Chuck Stadel 723

(1) Location of Well: Q NW NW 1/4 ~~SE~~ 1/4 of Section 7,
Township 18S, Range 12E, Deschutes County.

Address at well site or nearest known address: End of Powers
Rd Bend OR

(2) Name and address of Landowner: City of Bend
P.O. Box 431
Bend OR


(3) The distance to the nearest well and septic drainfield: 200' +

(4) The unusual conditions existing at the well site: N/A

(5) The proposed construction methods that the well constructor or landowner constructing the well believes will be adequate for his particular well:
17" bore hole to 548' 12" casing to 548', cement
grout from 548' up to 528', bent chips from
528' up to 150', cement grout from 150'
to land surface. Request use of bent chips
to eliminate grout loss in loss zones

W-SM
SC 36701

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



For Water Resources Department Use Only

Date:

Approved by:

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.



WELL SERVICES INC

TELECOPIER COVER LETTER

PLEASE DELIVER THE FOLLOWING PAGES TO:

NAME: Greg Beaman
FIRM: WRD
CITY: Salem
FAX NUMBER: 378-8130

DATE: 4/10/92
FROM: Chuck Stideli

TOTAL NUMBER OF PAGES INCLUDING COVER LETTER: 3

IF YOU DO NOT RECEIVE ALL PAGES, PLEASE CALL!!

ORIGINAL DOCUMENTS BEING SENT BY MAIL? YES _____ NO

REMARKS:

Please find enclosed request for special well construction standards for 12" well for the City of Bend.

Please call if you have any questions

Thanks

Chuck

STATE OF OREGON
WATER RESOURCES DEPARTMENTREQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT
INCLUDED IN THE RULES AND REGULATIONS PRESCRIBING GENERAL STANDARDS
FOR THE CONSTRUCTION AND MAINTENANCE OF WELLS IN OREGON

Before approval can be considered the following questions must be answered.

Requests shall be submitted to the Watermaster Division, 3850 Portland Road, NE, Salem, OR 97310.

Date: 4/9/92

Well Constructor: STACO Well Services

Chuck Stadler 723

(1) Location of Well: Q NW 1/4 114 ~~SE~~ 1/4 of Section 7,

Township 18S, Range 12E, Deschutes County.

Address at well site or nearest known address: End of Powers
Rd Bend OR

(2) Name and address of Landowner: City of Bend

P.O. Box 431

Bend OR

(3) The distance to the nearest well and septic drainfield: 200' +


(4) The unusual conditions existing at the well site: _____

N/A

(5) The proposed construction methods that the well constructor or landowner constructing the well believes will be adequate for his particular well:

17" bore hole to 548' 12" casing to 548', cement
grout from 548' up to 528', bent chips from
528' up to 150', cement grout from 150'
to land surface. Request use of bent chips
to eliminate grout loss in loss zones

(6) A diagram showing the pertinent features of the proposed well design and construction (attach additional sheet if necessary):



For Water Resources Department Use Only

Date:

Approved by:

Denied by:

Remarks:

NOTE:

- (1) If approval, all other phases of construction must be in compliance with State Well Construction Standards.
- (2) If it should be determined at some future date that the well, due to its construction, is offering an avenue for pollution of the ground water body, it will be necessary for you to return to the site to correct any well deficiencies.

84150