



Oregon

Theodore R. Kulongoski, Governor

ev 4-15-04

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1271
503-986-0900
FAX 503-986-0904

April 13, 2004

SKYLES DRILLING
STEVEN C BLAND #1592
1169 MOLALLA AVENUE
OREGON CITY OR 97045

FINAL ORDER


Dear Mr. Bland:

The special standard request you submitted for owner: Ron and Sue Johnston, start card number 163956 is approved for the following: reduced annulus in the lower seal (eccentric drilling), the lower seal shall be 15 feet, rather than the minimum 5 feet. See Oregon Administrative Rule (OAR) 690-210-0150. Your special standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at tracy.l.eichenlaub@wrд.state.or.us.

Respectfully,


Ms. Tracy Eichenlaub
Well Construction Specialist
Enforcement Section

enclosure

cc: Kris Byrd, NW Region Well Inspector

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137.004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order.

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 4/12/04 Oral approval date (if applicable): 4/12/04

Bonded Well Constructor (name, license #, and mailing address): Steven C. Bland¹

#1592 1169 Molalla Ave., Oregon City, OR 97045

(1) Location of Well: SE 1/4 SW 1/4 Tax lot 500 Section 05,

Township 1 S N, Range 4 E W, Multnomah County

Address at well site: 1918 SE 302nd Ave.

Troutdale, OR 97060

(2) Start Card Number(s)(for work to be done): 163956

(3) Name and Address of Land Owner: Ron + Sue Johnston

1918 SE 302nd Ave., Troutdale, OR 97060

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)

OVER 100 FEET

(5) The unusual site conditions which necessitate this request: Sealing 10"

Casing with a lower seal hole of 11.8 inches.

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

Pump in cement grout under pressure providing a 15 foot seal at a depth between 181' and 198'. Sealed in consolidated formation.

RECEIVED


APR 13 2004

WATER RESOURCES DEPT
SALEM, OREGON

SKYLES DRILLING, INC.

W-AS
remarks: eccentric

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)



SKYLES DRILLING, INC.

PLEASE NOTE:

- (1) The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.
- (2) If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.
- (3) If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: Steven C. Bland

revised 11/15/2003

WELL BONDING CLERK