



Oregon

Theodore R. Kulongoski, Governor

e/ 2-23-04

Water Resources Department
North Mall Office Building
725 Summer Street NE, Suite A
Salem, OR 97301-1271
503-986-0900
FAX 503-986-0904

February 13, 2004

LARRY BURD WELL DRILLING
LARRY BURD # 544
70732 SW DOUGLAS
PENDLETON OR 97801

FINAL ORDER

Dear Mr. Burd:

The special standard request you submitted for owner: ???(not on special standard request), start card number 159904 is denied for the following: using 16 inch, .250 wall casing below 250 feet. See Oregon Administrative Rule (OAR) 690-210-0190(3). Your special standard request form is enclosed.

The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.

If you have any questions concerning this letter, please contact me at (503) 986-0851, or by e-mail at tracy.l.eichenlaub@wrд.state.or.us.

Sincerely,

Tracy Eichenlaub
Ms. Tracy Eichenlaub
Well Construction Specialist
Enforcement Section

enclosure

cc: Brian Mayer, NC Region Well Inspector

This is a final order in other than a contested case. This order is subject to judicial review under ORS 183.484. Any petition for judicial review of the order must be filed within the 60 day time period specified by ORS 183.484(2). Pursuant to ORS 536.075 and OAR 137.004-0080 and OAR 690-01-0005 you may either petition for judicial review or petition the Director for reconsideration of this order.

RECEIVED

FEB 13 2004

WATER RESOURCES DEPT.
SALEM, OREGON

Oregon Water Resources Department

REQUEST FOR WRITTEN APPROVAL TO USE CONSTRUCTION METHODS NOT INCLUDED IN OREGON ADMINISTRATIVE RULES 690-200 THROUGH 690-240

Before the request can be considered, this form must be completed. Requests shall be submitted to the Well Construction Specialist, Water Resources Department, 725 Summer Street NE, Suite "A", Salem OR 97301-1271. Requests may also be considered by the appropriate Regional Manager.

Date of request: 2-11-2004 Oral approval date (if applicable): _____

Bonded Well Constructor (name, license #, and mailing address): LARRY BURD

70732 S W DOUGLAS. PENDLETON, OR 97801

(1) Location of Well: NW 1/4 NW 1/4 Tax lot 2000 Section 24,

Township 1 S, Range 26 E, MORROW County

Address at well site: RT 2 SANDHOLLOW ROAD, HEPPNER, OR 97836

(2) Start Card Number(s)(for work to be done): 159904

(3) Name and Address of Land Owner: SAME

(4) Distance to the nearest septic tank, drainfield, closed sewage line (if water supply well)
1000 +-

(5) The unusual site conditions which necessitate this request: SEE ATTACHED SHEET

(6) The proposed construction methods that the bonded well constructor believes will be adequate for this well: (attach additional pages if needed)

W-CA

- (7) Diagram showing the pertinent features of the proposed well design and construction:
(attach additional pages if needed)

PLEASE NOTE:

- (1) **The Well Construction Standards serve to protect ground water resources. By approving and issuing this special construction standard the Oregon Water Resources Department is not representing that a well constructed in accordance with this condition will maintain structural integrity or that it meets engineering standards. The well constructor/or landowner is responsible for ensuring that a well is constructed in a manner that protects ground water resources as required under Oregon Administrative Rules 690-200 through 690-240.**
- (2) **If it should be determined at some future date that the well, due to its construction, is allowing ground water contamination, waste or loss of artesian pressure, the undersigned shall return to the site and rectify the problem.**
- (3) **If oral approval was granted, a written request must be submitted to the Department either within three (3) working days of the date of oral approval or prior to the completion of the associated well work. Failure to submit a written request as described above may void prior oral approval.**

I have read and understand the above information. I further attest that the information provided is accurate to the best of my knowledge.

Bonded Constructor Signature: _____

Larry Burd